



 DECLARATION OF PERFORMANCE <i>In accordance with Construction Product Reg. EU N° 305/2011</i> N. 0051-CPR-3904/2017																																																					
1.	Unique product identification code:	AE300																																																			
2.	Intended use:	Voice alarm control and indicating equipment for fire detection and fire alarm systems																																																			
3.	Manufacturer:	KREA S.r.l. Via Abbiategrasso, 21 – 20046 Cisliano (MI) - Italy																																																			
4.	Representative:	Not Applicable																																																			
5.	VVCP system:	1																																																			
6a.	Harmonized standard:	EN54-16 and EN54-4																																																			
	Notified body:	N. 0051 IMQ S.p.A.																																																			
6b.	European Technical Assessment:	Not Applicable																																																			
7.	Declared performance:																																																				
	<table border="1"> <thead> <tr> <th colspan="3"><i>EN54-16 Harmonized standard</i></th> </tr> <tr> <th><i>Description</i></th> <th><i>Clause</i></th> <th><i>Performance</i></th> </tr> </thead> <tbody> <tr> <td>Performance under fire condition</td> <td>4, 5, 7, 10, 12, 16.5, 16.7</td> <td>PASS</td> </tr> <tr> <td>Response delay</td> <td>7.1, 7.4, 7.8, 12</td> <td>PASS</td> </tr> <tr> <td>Operational reliability</td> <td>4, 5, 6, 7, 8, 12, 13, 14</td> <td>PASS</td> </tr> <tr> <td>Durability of operational reliability, temperature resistance</td> <td>16.4, 16.8</td> <td>PASS</td> </tr> <tr> <td>Durability of operational reliability, impact and vibration resistance</td> <td>16.11, 16.12, 16.13</td> <td>PASS</td> </tr> <tr> <td>Durability of operational reliability, electrical stability</td> <td>16.14, 16.15</td> <td>PASS</td> </tr> <tr> <td>Durability of operational reliability, humidity resistance</td> <td>16.9, 16.10</td> <td>PASS</td> </tr> </tbody> </table> <table border="1"> <thead> <tr> <th colspan="3"><i>EN54-4 Harmonized standard</i></th> </tr> <tr> <th><i>Description</i></th> <th><i>Clause</i></th> <th><i>Performance</i></th> </tr> </thead> <tbody> <tr> <td>Performance of the power supply</td> <td>4, 5, 6</td> <td>PASS</td> </tr> <tr> <td>Operational reliability</td> <td>4, 5, 6, 7, 8</td> <td>PASS</td> </tr> <tr> <td>Durability of operational reliability, temperature resistance</td> <td>9.5</td> <td>PASS</td> </tr> <tr> <td>Durability of operational reliability, impact and vibration resistance</td> <td>9.7, 9.8, 9.15</td> <td>PASS</td> </tr> <tr> <td>Durability of operational reliability, electrical stability</td> <td>Da 9.9 a 9.13</td> <td>PASS</td> </tr> <tr> <td>Durability of operational reliability, humidity resistance</td> <td>9.6, 9.14</td> <td>PASS</td> </tr> </tbody> </table>		<i>EN54-16 Harmonized standard</i>			<i>Description</i>	<i>Clause</i>	<i>Performance</i>	Performance under fire condition	4, 5, 7, 10, 12, 16.5, 16.7	PASS	Response delay	7.1, 7.4, 7.8, 12	PASS	Operational reliability	4, 5, 6, 7, 8, 12, 13, 14	PASS	Durability of operational reliability, temperature resistance	16.4, 16.8	PASS	Durability of operational reliability, impact and vibration resistance	16.11, 16.12, 16.13	PASS	Durability of operational reliability, electrical stability	16.14, 16.15	PASS	Durability of operational reliability, humidity resistance	16.9, 16.10	PASS	<i>EN54-4 Harmonized standard</i>			<i>Description</i>	<i>Clause</i>	<i>Performance</i>	Performance of the power supply	4, 5, 6	PASS	Operational reliability	4, 5, 6, 7, 8	PASS	Durability of operational reliability, temperature resistance	9.5	PASS	Durability of operational reliability, impact and vibration resistance	9.7, 9.8, 9.15	PASS	Durability of operational reliability, electrical stability	Da 9.9 a 9.13	PASS	Durability of operational reliability, humidity resistance	9.6, 9.14	PASS
<i>EN54-16 Harmonized standard</i>																																																					
<i>Description</i>	<i>Clause</i>	<i>Performance</i>																																																			
Performance under fire condition	4, 5, 7, 10, 12, 16.5, 16.7	PASS																																																			
Response delay	7.1, 7.4, 7.8, 12	PASS																																																			
Operational reliability	4, 5, 6, 7, 8, 12, 13, 14	PASS																																																			
Durability of operational reliability, temperature resistance	16.4, 16.8	PASS																																																			
Durability of operational reliability, impact and vibration resistance	16.11, 16.12, 16.13	PASS																																																			
Durability of operational reliability, electrical stability	16.14, 16.15	PASS																																																			
Durability of operational reliability, humidity resistance	16.9, 16.10	PASS																																																			
<i>EN54-4 Harmonized standard</i>																																																					
<i>Description</i>	<i>Clause</i>	<i>Performance</i>																																																			
Performance of the power supply	4, 5, 6	PASS																																																			
Operational reliability	4, 5, 6, 7, 8	PASS																																																			
Durability of operational reliability, temperature resistance	9.5	PASS																																																			
Durability of operational reliability, impact and vibration resistance	9.7, 9.8, 9.15	PASS																																																			
Durability of operational reliability, electrical stability	Da 9.9 a 9.13	PASS																																																			
Durability of operational reliability, humidity resistance	9.6, 9.14	PASS																																																			
8.	Appropriate technical documentation and/or specific technical documentation:	Not applicable																																																			
	The performance of the product identified above is in conformity with the set of declared performances. This declaration of responsibility is issued, in accordance with Regulation (EU) No. 305/2011, under the sole responsibility of the manufacturer identified above.	Signed for and on behalf of the manufacturer by: Paolo Ferretti Cisliano, 05/04/2026 																																																			